




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



June 4, 2013

Mr. Brian Diyorio
Harsco Minerals PWS
101 Tidewater Road NE
Warren, OH 44483-2434

TRUMBULL COUNTY
HARSCO MINERALS PWS
NTNC PWS
PWS ID: OH7855312
VIO ID: 9430

Subject: Rescinding Violation – TCR

Dear Mr. Diyorio:


Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on 4/25/2013 for the monitoring period of 1Q2013. The sample was collected on 3/11/2013, but the result was not reported until 5/2/2013.

The violation has been rescinded, and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample was not reported in accordance with the above rules, and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact this office at 330-963-1242.

Sincerely,


Charlotte E. Hammar
Environmental Specialist
Division of Drinking and Ground Waters

CEH:dms

cc: Trumbull County Health Department
Cardinal Labs