



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

NOTICE OF VIOLATION – ACTION REQUIRED

May 15, 2013

Mr. Gary Greiwe
Green Meadows MHP
23135 State Route 235 Lot 2
Ada, Ohio 45810

Hancock
Richland County
Green Meadows MHP
Community PWS
PWS ID: OH3200812

Dear Mr. Greiwe:

Green Meadows MHP is in violation of Ohio Revised Code Chapter 6109 as follows:


In violation of OAC 3745-83-01(F)(5)(a)(i), the public water system failed to report iron at the plant tap on a weekly basis. There were three weeks during the month in which no analysis was reported.

Green Meadows MHP must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by May 30, 2013.

Beginning July 1, 2013, submit Monthly Operating Reports electronically using the eDWR web application: <http://epa.ohio.gov/ddagw/reporting.aspx>

If you have any questions, please contact me at (419) 373-3105 or by e-mail at curt.eldridge@epa.ohio.gov.

Sincerely,



Curtis Eldridge
Division of Drinking and Ground Waters

/cg

pc: Hancock County Health Department
DDAGW - NWDO

