



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

June 12, 2013

Ms. Virginia Grose
Walnut Hills Water
552 Morrison Avenue
Mansfield, Ohio 44904

Richland County
Walnut Hills Water
Community PWS
PWS ID: OH7005032

Dear Ms. Grose:

Walnut Hills Water is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. All five weeks during the month iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

- (a) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

In violation of OAC 3745-83-01(F)(6)(a)(i), the public water system failed to report manganese at the plant tap on a weekly basis. There were four weeks during the month in which no analysis was reported.


Altman Heights Community Water Association must take immediate action to resolve these violations. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by June 30, 2013.

Beginning July 1, 2013, submit Monthly Operating Reports electronically using the eDWR web application: <http://epa.ohio.gov/ddagw/reporting.aspx>

Ms. Virginia Grose
June 12, 2013
Page 2

If you have any questions, please contact me at (419) 373-3105 or by e-mail at curt.eldridge@epa.ohio.gov.

Sincerely,



Curtis Eldridge
Division of Drinking and Ground Waters

/cg

pc: Richland County Health Department
Marc Henke, Operator
DDAGW – NWDO