



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 5, 2013

RE: COLUMBIANA COUNTY  
SHADYBROOK MOBILE HOME PARK  
COMMUNITY PUBLIC WATER SYSTEM  
PWS # OH1566412  
STU ID # 1562496

Mr. Jay E. Householder Jr.  
Shadybrook Mobile Home Park  
49377 Hickman Road  
East Liverpool, OH 43920

Dear Mr. Householder:

This letter is notification that the Shadybrook Mobile Home Park (MHP) public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine measured at representative points throughout the distribution system.

This office has received detail plans for the water line connection to the Buckeye Water District. Once the plans are approved by this office, they will be sent to our Central Office for Director's Signature. Please keep this office informed on the progress with respect to connecting to the Buckeye Water District.

If you have any question, please contact me directly at (330) 963-1248.

Respectfully,

A handwritten signature in black ink, appearing to read 'J. Robert Henn', written in a cursive style.

J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

cc: Ohio Manufactured Homes Commission  
Kim Etters, Ohio EPA, NEDO, DDAGW