



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

June 3, 2013

Pastor Steve Rauch
Pleasant Chapel Church of God
3225 Old Mill Road
Lancaster, OH 43130

Fairfield County
Pleasant Chapel Church Of God
TRANSIENT NON COMMUNITY PWS
PWD ID: OH2353312

Dear Public Water System Owner:

The Public Water System serving PLEASANT CHAPEL CHURCH OF GOD PWS is in violation of the Ohio Administrative Code (OAC) for:

Sanitary Survey Violations

Failure to respond in Writing within 30 days

This letter is notification that the Pleasant Chapel Church of God has not complied with requirements issued during this Agency's last survey performed on April 8, 2013 in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated April 29, 2013 to respond in writing no later than 30 days, with time frames for:

1. Fill out the sample siting plan and maintain it on site, and please send a copy to this office.
2. Maintain all records pertaining to your public water system on site. These documents must be made available during future surveys.
3. Using the certified lab list provided in your survey letter, conduct an Ohio EPA complete well analysis.
4. Slope soils around the well head to promote positive drainage and protect the well with bumper posts or boulders.
5. Notify this office of any substantial changes to your water system before the changes are implemented.

Pastor Steve Rauch
Pleasant Chapel Church of God
Page -2-

6. Notify this office if your pressure drops below 20 psi.
7. Follow your contaminant monitoring schedule and ensure no bleach is detected when sampling for bacteria.

If you have any questions please call me at (614) 728-3871.

Sincerely,



Mark Boden
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)