



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

May 16, 2013

Mr. Tom Sears
Village of Farmersville
117 E. Walnut St.
Farmersville, OH 45325

**RE: Montgomery County
Farmersville, Village of
Community PWS
PWS ID: OH5700912
VIO ID: 8407410**

RE: Rescinding Violation - TCR

Dear Public Water System Owner:

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on April 18, 2013 for the March 2013 monitoring period. The sample was collected on March 7th, but the result was not correctly reported until April 22, 2013. Initially the reporting laboratory reported the sample under a different public water system (PWS) ID which resulted in the violation notice being sent to you.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The sample was not reported in accordance with the above rules and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact me at (937) 285-6117.

Sincerely,

John McDaniel
Environmental Specialist
Division of Drinking Water

JM/kb

ec: Montgomery County Health Department
cc: Belmont Labs

5/23