



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION

6/20/2013

Re: Hocking County
Village of Murray City
Class 1 Water Supply
PWSID: OH3700803

Sharon Koon
Mayor, Village of Murray City
PO Box 241
Murray City, OH 43144

Reference: Failure to Designate an Operator of Record

Our files indicate your public water system (PWS) is operating without an appropriately certified operator of record (ORC) in violation of Ohio Administrative Code (OAC) 3745-7-02(A)(1). OAC Rule 3745-7-02(A)(1) states: "the owner or operator of a public water system shall designate an operator of record with a certification of a class equal to or greater than the classification of the public water system, distribution system or water treatment plant".

Your facility is a Class 1 PWS; therefore a Class 1 or higher operator must be physically present at the facility for a minimum period of 3 days per week and 1.5 hour(s). In order to address the above referenced violation, the following actions are required:

1. Obtain an appropriately certified ORC to be the on-site certified operator who performs the technical operation of the public water system; and
2. Complete the enclosed ORC Notification Form. Mail or fax the form to the address listed at the top of the form within **15 days of the date of this letter**.

In the event you need assistance in finding an appropriately certified operator you may use Ohio EPA's Contract Operator's List at the following link to assist you:

http://epa.ohio.gov/portals/28/documents/opcert/contract_operator_list.pdf

If you should have any questions, please contact Dave Riley at (614) 644-2752

Sincerely,

A handwritten signature in black ink that reads "Andrew Barienbrock". The signature is written in a cursive, flowing style.

Andrew Barienbrock, Environmental Supervisor
Division of Drinking and Ground Waters
Enclosure: Operator of Record Notification form

cc: SEDO District
Operations File