




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



June 24, 2013

Mr. Greg Hogue
Orwell Village PWS
P.O. Box 354
Orwell, OH 44076

ASHTABULA COUNTY
ORWELL VILLAGE PWS
COMMUNITY PWS
PWS ID: OH0401012
VIO ID: 8016611

Subject: Rescinding Violation – TCR

Dear Mr. Hogue:

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on 3/22/2012 for the monitoring period of Feb 01/2012. The samples were collected on February 1, 2012, but the result was not reported correctly.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued at this time.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the 10th day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The samples were not reported in accordance with the above rules, and this is considered a reporting violation.

Please ensure future sample results are submitted as required. If you have any questions, please contact this office at 330-963-1199.

Sincerely,

*Beth Madis for
Steve Bopple*
Stephen Bopple, P.E.
Environmental Specialist
Division of Drinking and Ground Waters

SB:ds

cc: Ashtabula County Health Department
Geauga Co. Dept. of Water Resources