



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 24, 2013

RE: PORTAGE COUNTY  
MODERN MANAGEMENT – ALL SEASONS  
COMMUNITY WATER SYSTEM  
PWS ID # OH6700812

**NOTICE OF VIOLATION**

Ms. Carol Foster  
263 West Main Street  
Suite A  
Ravenna, OH 44266

Dear Ms. Foster:

This letter is notification that the All Seasons MHP public water system exceeded the secondary maximum contaminant levels for iron and manganese for the month of April 2013. Ohio Administrative Code Rule 3745-82-02 defines the Secondary Maximum Contaminant Level (SMCL) for iron to be 0.3 mg/L and the SMCL for manganese to be 0.05 mg/L. Iron and manganese were analyzed on four days in April 2013 and the SMCLs were exceeded on all four days. Operational corrections must be made immediately to ensure that the SMCLs for iron and manganese are not exceeded.

If you have any questions, I can be contacted directly at (330) 963-1182.

Respectfully,

A handwritten signature in blue ink that reads "Laurel Ljubi".

Laurel Ljubi  
Environmental Specialist  
Division of Drinking and Ground Waters

LL:ds

cc: Mike Fletcher, Operator  
Toni Buchanan, Ohio EPA, DDAGW, CO  
Kim Eters, Ohio EPA, DDAGW, NEDO  
ec: Laurel Ljubi, Ohio EPA, DDAGW, NEDO