



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 24, 2013

RE: PORTAGE COUNTY
MODERN MANAGEMENT - PM ESTATES
COMMUNITY WATER SYSTEM
PWS ID #OH6700612

NOTICE OF VIOLATION

Ms. Carol Foster
263 West Main Street
Suite A
Ravenna, OH 44266

Dear Ms. Foster:

This letter is notification that the PM Estates public water system exceeded the secondary maximum contaminant level for manganese for the month of April 2013. Ohio Administrative Code Rule 3745-82-02 defines the Secondary Maximum Contaminant Level (SMCL) for manganese to be 0.05 mg/L. Manganese was analyzed every day during the month of April and exceeded the SMCL on five days. Operational corrections must be made immediately to ensure that the SMCL for manganese is not exceeded.

If you have any questions, I can be contacted directly at (330) 963-1182.

Respectfully,

Laurel Ljubi
Environmental Specialist
Division of Drinking and Ground Waters

LL:ds

pc: Mike Fletcher, Operator
Toni Buchanan, Ohio EPA, DDAGW, CO
Kim Etters, Ohio EPA, NEDO, DDAGW

ec: Laurel Ljubi, Ohio EPA, DDAGW, NEDO