



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

June 12, 2013

Stephen Clapper  
P.O. Box 163  
Orient, OH 43146

**Pickaway County  
Village Of Orient  
COMMUNITY PWS  
PWS ID: OH6503703**

Dear Mr. Clapper:

The Village Of Orient is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required (free/combined) chlorine residuals (two-tenths milligram per liter free chlorine / one milligram per liter combined chlorine) throughout the distribution system. There were 16 days during the month of May in which the minimum chlorine residual was not maintained. Furthermore it is noted that this violation has occurred for the third month out of the last 12. A report must be submitted within 30 days identifying the problem and corrective actions necessary to ensure that minimum chlorine residuals will be provided.

The Village Of Orient must take immediate action to resolve these violations. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

Should you have any questions regarding this notice of violation, please contact me at (614) 728-3870 or at [bridgette.marchio@epa.state.oh.us](mailto:bridgette.marchio@epa.state.oh.us).

Sincerely,

Bridgette Marchio  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

ec/pc: Pickaway County Health Department  
Steve Sherrick

BM/ct 6503703(MI)May2013