



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

June 17, 2013

Geoffrey W. Burns  
1380 Blue Valley Road  
Lancaster, OH 43130-9021

Fairfield County  
Geneva Hills Residence  
TRANSIENT NON-COMMUNITY PWS  
PWS ID: OH2332212

Dear Mr. Burns:

The Public Water System serving GENEVA HILLS RESIDENCE is in violation of the Ohio Administrative Code (OAC) for:

Failure to obtain plan approval for an installed waterline extension

On June 14, 2013, this office received notification from the Fairfield County Health Department of a waterline extension from Calvin Cottage to the Geneva Hills Pool. Calvin Cottage is part of the Geneva Hills Residence distribution system. Your water system has installed new waterline from the Geneva Hills Residence system to serve the Geneva Hills Pool system without receiving plan approval from Ohio EPA and is a violation of Ohio Administrative Code (OAC)3745-91-02.

The installation of new waterline and connection to another distribution system are both considered substantial changes to the distribution and source as defined in OAC 3745-91-01. Both changes require plans to be approved by Central District Office before installation. The waterline recently installed from Calvin Cottage to the Geneva Hills Pool system must be removed from service until detail plan approval has been achieved.

If you have any questions please call my office at (614) 728-3870.

Sincerely,

A handwritten signature in black ink that reads "Bridgette Marchio".

Bridgette Marchio  
Environmental Specialist  
Division of Drinking and Ground Waters  
Central District Office

c: Fairfield County Health Department  
ec: Ken Egbert, Jr., AGO  
Julie Spangler, CO, DDAGW

BM/ct 2332212(PA)JUN2013