

NOTICE OF VIOLATION – ACTION REQUIRED

July 3, 2013

Mr. Mike Leis
Beaverdam Water Treatment Plant
101 West Main Street
Beaverdam, Ohio 45808

Allen County
Beaverdam Water Treatment Plant
Community PWS
PWS ID: OH0200012

Dear Mr. Leis:

Beaverdam Water Treatment Plant is in violation of Ohio Revised Code Chapter 6109 as follows:


In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were two weeks during May 2013 in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Beaverdam Water Treatment Plant must take immediate action to resolve this/these violation(s). Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.



Mr. Mike Leis
July 3, 2013
Page 2

If you have any questions, please contact me at (419) 373-3007 or by e-mail at clayton.mckee@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, appearing to read 'Clayton McKee', with a stylized flourish at the end.

Clayton McKee
Division of Drinking and Ground Waters

/cg

pc: Allen County Health Department
DDAGW – NWDO

ec: Linda Benham, Environmental Supervisor, NWDO, DDAGW
Clayton McKee, NWDO, DDAGW

