



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

July 3, 2013

Mr. Randy Bufford  
Richland Manor Nursing Home  
303 North Hurstbourne Parkway  
Suite 200  
Louisville, Kentucky 40222-5158

Allen County  
Richland Manor Nursing Home  
Community PWS

PWS ID: OH0201112

Dear Mr. Bufford:

Richland Manor Nursing Home is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required (free/combined) chlorine residual in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than (two-tenths milligram per liter free chlorine / one milligram per liter combined chlorine). There were 7 days during May 2013 in which the minimum chlorine residual was not maintained.

Richland Manor Nursing Home must take immediate action to resolve this/these violation(s). Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

If you have any questions, please contact me at (419) 373-3007 or by e-mail at [clayton.mckee@epa.ohio.gov](mailto:clayton.mckee@epa.ohio.gov).

Sincerely,

Clayton McKee  
Division of Drinking and Ground Waters

/cg

pc: Allen County Health Department  
DDAGW – NWDO

ec: Linda Benham, Environmental Supervisor, DDAGW, NWDO  
Clayton McKee, DDAGW, NWDO

