



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

June 25, 2013

Charles Santee  
7398 State Route 42  
Mount Gilead, OH 43338

Morrow County  
Apple Pie Inn  
TRANSIENT NON-COMMUNITY PWS  
PWS ID: OH5941412

Dear Public Water System Owner:

The Public Water System serving APPLE PIE INN is in violation of the Ohio Administrative Code (OAC) for:

**Failure to respond in Writing within 30 days**

*This letter is notification that the Apple Pie Inn has not complied with requirements issued during this Agency's last survey performed on May 9, 2013 in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated May 20, 2013, to respond in writing no later than 30 days, with time frames for:*

1. Fill out the enclosed sample siting plan and maintain it on site, and please send a copy of the first page to this office. This is your backup plan in the event your main lab or your main sampler is unable to analyze or pull your routine quarterly total coliform sample. In addition, it also explains what to do in the event of a positive sample and outline procedures for pulling your routine sample each calendar quarter. For your total coliform sampling, please make your lab and sampler aware that a digital DPD chlorine tester must be used to determine if any chlorine residual is in the water and those results must be placed and the Sample Submission Report (SSR).
2. Maintain all records pertaining to your public water system on site, including the date and nature of any repairs or remedial actions taken, owner/operator manuals for critical units, including the well pump and pressure tank, correspondence from this agency, sample results from your laboratory, the bacteriological sample siting plan and your well log from your driller. These documents must be made available during future surveys.
3. Notify this office of any substantial changes to your water system before the changes are implemented. I gave you a copy of our plan approval package during the survey, feel free to pass it along to your contractor (Lou at Peacock Water) if you elect to install a softener. Do not install the softener, or any treatment, without prior approval from this office.


Charles Santee

Page -2-

4. Ensure your nitrate sample is pulled anytime between June 1 and November 30, 2013.
5. Do not routinely disinfect your well (you indicated you use 3 gallons of bleach and 1 gallon of vinegar every 3 weeks). This may mask any bacterial issues with your water system. It is imperative that you obtain a representative sample for total coliform analysis each quarter. You indicated you did not have any problems with the untreated water with respect to taste and odor. If the well or water system is bacteriologically unsafe, you may need a new source, you may need to treat the water to a much higher degree of water treatment, or you may need to address a deficiency such as the illegal casing extension.
6. With regards to your PVC casing extension on your steel well: In accordance with the Bilateral Compliance Agreement, you had until April 14, 2013 to complete work on the well. You indicated you would be making arrangements with your contractor on May 15, let me know what date he will be out there. Do not fill in the hole unless I am on site or you have photos to send me showing the new steel casing extension is welded onto the existing casing. Ensure the contractor installs the cap and conduit properly. The cap currently does not have any nuts or bolts in it and the conduit is not attached properly to the cap. I sent you an email on May 16 asking about your May 15 meeting.
7. Keep the protective cover on the pressure switch and ensure all wiring to and from the switch is encased in conduit.
8. A combined public notice was given to you during the survey. You indicated it would be posted tomorrow and left up for 7 days. Although I have a signed copy of the notice and verification form (I asked you to complete and sign another copy of the combined notice and verification form during the survey), please return a completed copy of the notice you posted and the verification form to this office. Do ensure the notice is up for at least 7 days, no less.

If you have any questions please call your Ohio EPA representative at 614-728-3871.

Sincerely,



Mark Boden  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

ec: CDO DDAGW AA (State Violation)