





John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Seneca County
Fostoria Mobile Estates
Community Water System
PWS ID # OH7400712

July 25, 2013

Mr. Ace Elsea
Fostoria Mobile Estates
P.O. Box 580
Circleville, Ohio 43113

Dear Mr. Elsea:

This letter will confirm removal of the water use advisory required in our letter dated July 19, 2013. This is based on one set of four total coliform negative (safe) samples collected on July 11, 2013 and received by our office on July 23, 2013.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, Ohio 43402 by August 8, 2013.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of August 2013.

Yours truly,


Elizabeth Ames
Division of Drinking and Ground Waters

/cg

pc: Seneca County Health Department
DDAGW, NWDO

