



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 25, 2013

RE: STARK COUNTY
SHADY KNOLL MHP
COMMUNITY WATER SYSTEM
PWS ID #OH7605012

CERTIFIED MAIL 7010106000000898589

Ms. Clarissa Wiener, Owner
Shady Knoll MHP
202 East Summit Street
Kent, OH 44240

Dear Ms. Wiener:

The Shady Knoll MHP public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to monitor the free or combined chlorine daily, from the entry point (plant tap) and from the distribution system.

A review of the monthly operating reports (MORs) indicates the chlorine residuals are still not being monitored from the entry point (plant tap). In addition, the MORs are not properly filled out. The MORs must show: the public water system identification number (PWS ID NO) at the top of the MOR; the maximum, minimum and average chlorine values and the date the operator of record signs the MOR at the bottom of the MOR.

These issues have previously been discussed with your operator of record and your staff. Failure to properly fill out the MOR will result in additional violations.


To return to compliance, Shady Knoll MHP must submit a properly completed MOR to this office by the 10th day of the following month.

SHADY KNOLL MHP
JULY 25, 2013
PAGE 2 OF 2

Please note, beginning with July 2014, the MORs will be required to be submitted using the electronic Drinking Water Reporting program (eDWR). To begin using eDWR reporting, contact Brian Tarver in our Columbus Office. Brian will help you with the initial steps to start using eDWR. You may contact Brian at brian.tarver@epa.ohio.gov or (614) 644-2752.

If you have any questions, please contact me at (330) 963-1236.

Respectfully,



Dave Bowland
Environmental Specialist II
Division of Drinking and Ground Waters

DB:ds

cc: Bob Earmsberger, Operator of Record
Kim Ethers, Ohio EPA, DDAGW, NEDO
Ohio EPA, DDAGW-OFAS, CO

ec: Stivo DiFranco, Ohio EPA, DDAGW, NEDO
Gary.Whitaker@OMHC.state.oh.us