



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



May 15, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

Willard Buckler  
Waverly City  
P.O. Box 228, 211 W. North Street  
Waverly, OH 45690

Pike County  
Waverly City  
Community  
PWS ID: OH6600912

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During May 2013 (Monthly)**

Waverly City PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Public Notice wrapped into the Acute Violation (Type 21) Letter sent on 5/13/2013. This Type 22 and the Type 21 violation must be noted in your 2013 CCR.**
- 3. Complete the Acute Violation Type 21 Public Notice verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - SEDO. Include a copy of each notice distributed, published or posted.
- 4. Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at this office at 740-380-5229.

Sincerely,

Russell Flagg  
Environmental Specialist III

RF/cb

cc: Pike County Health Department  
District File Copy