



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



June 20, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Perry Atkinson
Winfield United Methodist Church PWS
5247 State Rte 516 NW
Dover, OH 44622

Tuscarawas County
Winfield United Methodist Church PWS
Non-Community, Transient PWS
PWS ID: OH7947612

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During June 2013 (Monthly)**

Winfield United Methodist Church PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Use the Tier 1 public notice sent under separate cover within 24 hours as required by OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - SEDO. Include a copy of each notice distributed, published or posted.

Winfield United Methodist Church PWS

June 20, 2013

Page 2

4. **Discontinue the Water Use Advisory** – As stated in the separate Acute letter, The water use advisory shall remain in effect until one set of four (4) repeat samples is total coliform-negative. Notify the people served by the water system when the water use advisory is discontinued.
5. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 740-380-5299.

Sincerely,

A handwritten signature in black ink that reads "Michael Carper". The signature is written in a cursive, flowing style.

Michael Carper
Environmental Specialist 2

MC/cb

cc: Tuscarawas County Health Department
District File Copy