



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

F

August 8, 2013

RE: **NOTICE OF VIOLATION**
MEDINA COUNTY
CLOVERLEAF MHP
COMMUNITY WATER SYSTEM
PWS ID # OH5200012

Mr. Yun Pan
Cloverleaf MHP
4086 Boston Road, Lot 9
Brunswick, Ohio 44212

Dear Mr. Pan:

This letter is notification that the Cloverleaf Mobile Home Park public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Cloverleaf Mobile Home Park PWS as reported on Monthly Operating Report (MOR) #5002 for June, 2013. Results reported on the form indicated eight days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation should be conducted to determine why the low residual occurred and what corrective action is necessary.

If you have any questions, please contact me directly at (330) 963-1202.

Respectfully,

Anne Karney
Environmental Specialist
Division of Drinking and Ground Waters

AK/ams

cc: Kim Ethers, Ohio EPA, NEDO, DDAGW
Richard Diehl, Cloverleaf MHP