




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



August 5, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Mike Leis
Beaverdam Water Treatment Plant
101 West Main Street
Beaverdam, Ohio 45808

Allen County
Beaverdam Water Treatment Plant
Community PWS
PWS ID: OH0200012

Dear Mr. Leis:

Beaverdam Water Treatment Plant is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required (free/combined) chlorine residual in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than (two-tenths milligram per liter free chlorine / one milligram per liter combined chlorine). There were seven (7) days during June 2013, in which the minimum chlorine residual was not maintained.

Beaverdam Water Treatment Plant must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

If you have any questions, please contact me at (419) 373-3007 or by e-mail at clayton.mckee@epa.ohio.gov.

Sincerely,

Handwritten signature of Clayton McKee in black ink.

Clayton McKee
Division of Drinking and Ground Waters

/llr

pc: Allen County Health Department
DDAGW – NWDO

ec: Clayton McKee, DDAGW, NWDO
Tyler Leggett, DDAGW, NWDO

