





John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Huron County  
Freedom Valley of Huron County  
TNC Water System  
PWS ID # OH3946412

July 31, 2013

Mr. Michael Folkman  
Freedom Valley of Huron County LLC  
P.O. Box 30  
New London, Ohio 44851

Dear Mr. Folkman:

This letter will confirm removal of the water use advisory required in our letter dated July 18, 2013. This is based on one set of four total coliform negative (safe) samples collected July 24, 2013.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of August 2013.

Yours truly,

Janis D'Amico  
Division of Drinking and Ground Waters

/cg

pc: Huron County Health Department  
DDAGW, NWDO

