



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

August 16, 2013

Mr. Kevin R. Ackerman
Milan Village
11 South Main Street
P.O. Box 1450
Milan, Ohio 44846

Erie County
Milan Village
Community PWS
PWS ID: OH2201212

Dear Mr. Ackerman:

Milan Village is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There were two weeks during the month of June 2013 in which iron exceeded the secondary standard.

Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

If you have any questions, please contact me at (419) 373-3108 or by e-mail at janis.damico@epa.ohio.gov.

Sincerely,

A handwritten signature in cursive script that reads "Janis D'Amico".

Janis D'Amico
Division of Drinking and Ground Waters

/cg

pc: Erie County Health Department
DDAGW – NWDO

