



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



August 26, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Anthony Zimmerman
9420 Bellefontaine Road
New Carlisle, Ohio 45344

**Clark County
Tecumseh Court MHP
Community PWS
PWS ID: OH1204512**

Dear Mr. Zimmerman:

Tecumseh Court MHP is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (F)(2), the public water system failed to report (free/combined) chlorine residual daily at the plant tap/distribution system. There were 4 days during the month of July 2013 in which the analysis was not performed.

Tecumseh Court MHP must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by September 22, 2013.

If you have any questions, please contact me at (937) 285-6085.

Sincerely,

Tya Darden
Environmental Specialist II
Division of Drinking and Ground Waters

TD/tb

ec: Clark County Health Department
Jared Rose, Ohio Manufactured Homes Commission