



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



August 26, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Don McMahan
8035 Meeker Road
Dayton, Ohio 45414

**Clark County
Park Terrace MHP
Community PWS
PWS ID: OH1203712**

Dear Mr. McMahan:

Park Terrace MHP is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required (free/combined) chlorine residual in the distribution system when the residual disinfectant concentration of the drinking water, at representative points throughout the distribution systems, was less than (two-tenths milligram per liter free chlorine / one milligram per liter combined chlorine). There were 4 days during the month of July 2013 in which the minimum chlorine residual was not maintained.

Park Terrace MHP must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by September 22, 2013.

If you have any questions, please contact me at (937) 285-6085.

Sincerely,

Tya Darden
Environmental Specialist II
Division of Drinking and Ground Waters

TD/tb

cc: Clark County Health Department
Jared Rose, Ohio Manufactured Homes Commission