





John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Hancock County
University of Findlay-South Campus
NTNC Water System
PWS ID # OH3244912

August 27, 2013

Mr. Martin Terry
University of Findlay-South Campus
1000 North Main Street
Findlay, Ohio 45840

Dear Mr. Terry:

This letter will confirm removal of the water use advisory required in our letter dated July 30, 2013. This is based on one set of four total coliform negative (safe) samples collected August 20, 2013.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by September 10, 2013.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of September 2013. You are also required to collect two additional routine samples during the month of August 2013.

Yours truly,

A handwritten signature in black ink that reads 'Jill A. Schiefer'. The signature is written in a cursive, flowing style.

Jill A. Schiefer
Division of Drinking and Ground Waters

/llr

pc: Hancock County Health Department
DDAGW, NWDO

(

(