




Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



August 19, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

CERTIFIED MAIL

David J Goodman  
Hunt Club Apartments PWS  
12929 Shaker Blvd,  
Cleveland, OH 44120

Summit County  
Hunt Club Apartments PWS  
Community PWS  
PWS ID: OH7700009  
Facility ID: DS1

**Subject: Violation of Maximum Contaminant Level for TOTAL HALOACETIC ACIDS (HAA5)**

Hunt Club Apartments PWS is in violation for exceeding the maximum contaminant level (MCL) standard of 0.060 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TOTAL HALOACETIC ACIDS (HAA5). Compliance with the MCL is based on a running annual average. The annual average for TOTAL HALOACETIC ACIDS (HAA5) during the Second Quarter of 2013 time period is 0.061 MG/L.

**To address the MCL violation,** Hunt Club Apartments PWS is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the mailing address below within ten days after issuance.
3. Perform quarterly monitoring for TOTAL HALOACETIC ACIDS (HAA5) according to your most recent monitoring schedule.
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any previously issued enforcement action.
5. For a community water system, include in the Consumer Confidence Report (CCR) a clear explanation of the violation including the length of the violation, the potential adverse health effects, and actions taken by the system to address the violation. The mandatory health effects language for the particular contaminant is specified in the appendix to OAC section 3745-96-02.

**Your prompt attention to this matter is greatly appreciated.** Continued noncompliance may lead to additional enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Michael W. Deal  
Compliance Assurance Section  
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form  
cc: Summit County Health Department

50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 644 3020  
614 | 644 3184 (fax)  
www.epa.ohio.gov

# DRINKING WATER NOTICE

## Hunt Club Apartments PWS Has Levels of TOTAL HALOACETIC ACIDS (HAA5) above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TOTAL HALOACETIC ACIDS (HAA5). The average level of TOTAL HALOACETIC ACIDS (HAA5) over the last four quarters was 0.061 MG/L. The standard for TOTAL HALOACETIC ACIDS (HAA5) is 0.060 MG/L.

### What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: \_\_\_\_\_.

Phone Number: \_\_\_\_\_.

Mailing Address: \_\_\_\_\_.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

Date Distributed: \_\_\_\_\_

PWSID: OH7700009 Facility ID: DS1

Monitoring Period: Second Quarter of 2013

# DRINKING WATER NOTICE

## Hunt Club Apartments PWS Has Levels of TOTAL HALOACETIC ACIDS (HAA5) above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TOTAL HALOACETIC ACIDS (HAA5). The average level of TOTAL HALOACETIC ACIDS (HAA5) over the last four quarters was 0.061 MG/L. The standard for TOTAL HALOACETIC ACIDS (HAA5) is 0.060 MG/L.

### What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: \_\_\_\_\_.

Phone Number: \_\_\_\_\_.

Mailing Address: \_\_\_\_\_.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

Date Distributed: \_\_\_\_\_

PWSID: OH7700009 Facility ID: DS1

Monitoring Period: Second Quarter of 2013

