



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



August 30, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. James A. Meyer
Village of McGuffey
810 South Gilbert Street
P. O. Box 304
Ada, Ohio 45810

Hardin County
Village of McGuffey
Community PWS
PWS ID: OH3300712
STU ID: 3354889

Dear Mr. Meyer:

Village of McGuffey PWS is in violation of Ohio Revised Code (ORC) Chapter 6109 as follows:

In violation of Ohio Administrative Code (OAC) Rule 3745-83-01(F)(5)(a)(ii), the public water system failed to report iron at the plant tap during July 2013. Monitoring is required either five (5) days per week with an in-house test kit or weekly by a state certified laboratory. There was one (1) week during the month in which no analysis was reported.

McGuffey Village must take immediate action to prevent future iron monitoring violations. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

If you have any questions, please contact me at (419) 373-3102 or by e-mail at kimberly.burnham@epa.ohio.gov.

Sincerely,

Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

/llr

pc: Hardin County Health Department
File: DDAGW – NWDO

