




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

August 27, 2013

Mr. Alan Word
Williams Co/Hillside Country Living
One Courthouse Square
4th Floor
Bryan, Ohio 43506

Williams County
Williams County Hillside Country Living
Community PWS
PWS ID: OH8601912

Dear Mr. Word:

Williams Co/Hillside Country Living is in violation of Ohio Revised Code Chapter 6109 as follows:


In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. There were two weeks during July 2013 in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(5) to determine compliance with the secondary maximum contaminant level for iron.
- (b) A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for iron does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

Williams Co/Hillside Country Living must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules.



Mr. Alan Word
August 27, 2013
Page 2

If you have any questions, please contact me at (419) 373-3007 or by e-mail at clayton.mckee@epa.ohio.gov.

Sincerely,



Clayton McKee
Division of Drinking and Ground Waters

/cg

pc: Williams County Health Department
DDAGW – NWDO

ec: Clayton McKee, NWDO, DDAGW

