



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



\* D D G W 0 H 1 1 0 1 3 1 2 8 7 3 0 9 3 6 \*

June 27, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. William L. Neer  
P. O. Box 790  
Urbana, Ohio 43078

RE: Champaign County  
Valley View Mobile Home Park  
Community PWS  
PWS ID: OH1101312

Dear Mr. Neer:

Valley View Mobile Home Park is in violation of Ohio Revised Code Chapter 6109 as follows:

Failure to maintain the minimum required (free or combined) chlorine residual in the distribution system; 3 days or more - NOV 3745-83-01 (C)(1). In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required (free/combined) chlorine residual in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than (two-tenths milligram per liter free chlorine / one milligram per liter combined chlorine). There were 7 days during the month in which the minimum chlorine residual was not maintained.


Furthermore, it is noted that this violation has occurred for the third month out of the last 12. A report must be submitted within 30 days identifying the problem and corrective actions necessary to ensure that minimum chlorine residuals will be provided.

Valley View Mobile Home Park must take immediate action to resolve this/these violation(s). Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by July 31, 2013.

Valley View Mobile Home Park  
Notice of Violation – Community PWS ID: OH1101312  
June 27, 2013  
Page 2

If you have any questions, please call me at (937) 285-6085 or email me at [tya.darden@epa.ohio.gov](mailto:tya.darden@epa.ohio.gov).

Sincerely,

A handwritten signature in black ink that reads "Tya Darden". The signature is written in a cursive, flowing style.

Tya Darden  
Environmental Specialist II  
Division of Drinking and Ground Waters

TD/tb

cc: Clark County Health Department  
Brad Hudson