



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 6, 2013

RE: MAHONING COUNTY
GLEN AT STATE LINE MHP #1
COMMUNITY PUBLIC WATER SYSTEM
PWS ID #OH5002812
NOTICE OF VIOLATION

Mr. Dan Kiely, Owner
Glen at State Line Mobile Home Parks
301 North Clematis Street, Suite 3000
West Palm Beach, FL 33401

Dear Mr. Kiely:

This letter is notification that the Glen at State Line MHP #1 Public Water System (PWS) is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to monitor or maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points in the distribution system.

This violation of the OAC is based upon information submitted by the Glen at State Line MHP #1 PWS as reported on Monthly Operating Report (MOR) #5002 for the months of **May - July 2013**. Below is a table which indicates the reporting months and the number of days when the free chlorine residual was less than 0.2 mg/L or was not recorded.

Reporting Month	Number of days the free chlorine residual < 0.2 mg/L
May 2013	9
June 2013	10
July 2013	23

An evaluation/investigation and corrective action should be taken to rectify this situation. Please provide a written explanation, within 14 days of the date of this letter, outlining the corrective action you have taken.

If you have any questions, please contact me directly at (330) 963-1164.

Respectfully,

Chris Maslo
Environmental Specialist
Division of Drinking and Ground Waters

CM:dl

cc: Ed Janosky, Certified Operator
ec: Kim Eppers, Ohio EPA, DDAGW, NEDO
Gary Whitaker