



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

September 6, 2013

Ms. Julie Vantaggi
IRBW Properties, Ltd. dba Willard MHP
6 Corporation Center
Broadview Heights, Ohio 44147

Huron County
IRBW Properties, Ltd. dba Willard MHP
Community PWS
PWS ID: OH3901612

Dear Ms. Vantaggi:

IRBW properties, Ltd. dba Willard MHP is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required combined chlorine residual in the distribution system when the residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than (one milligram per liter combined chlorine. There were five (5) days during the month of July 2013 in which the minimum chlorine residual was not maintained.

IRBW Properties, Ltd. dba Willard MHP must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action.

If you have any questions, please contact me at 419-373-3108 or by e-mail at janis.damico@epa.ohio.gov.

Sincerely,

Janis D'Amico
Division of Drinking and Ground Waters

/cg

pc: Huron County Health Department
DDAGW – NWDO

ec: Ohio Manufactured Homes Commission

