




John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



## NOTICE OF VIOLATION – ACTION REQUIRED

September 6, 2013

Mr. Charles F. Rowalt  
Spring Valley Mobile Home Park  
5913 Spring Valley Court  
Galion, Ohio 44833-9511

Crawford County  
Spring Valley Mobile Home  
Community PWS  
PWS ID: OH1700612

Dear Mr. Rowalt:

Spring Valley Mobile Home Park is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There was one week during the month of July 2013 in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

If you have any questions, please contact me at 419-373-3108 or by e-mail at [janis.damico@epa.ohio.gov](mailto:janis.damico@epa.ohio.gov).

Sincerely,

Janis D'Amico  
Division of Drinking and Ground Waters

pc: Crawford County Health Department  
DDAGW – NWDO  
ec: Ohio Manufactured Homes Commission

/cg

