



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



September 6, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Barbara Weikart-Kuder
Stoneridge Terrace
33807 Winona Road
Salem, OH 44460

COLUMBIANA COUNTY
STONERIDGE TERRACE
NON-COMMUNITY, TRANSIENT PWS
PWS ID # OH1558012

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During August 2013 (Monthly)**

Stoneridge Terrace is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** You are required to issue the appropriate public notice within 30 days in accordance with OAC Rule 4745-81-32. I met with you on September 4, 2013 to help you investigate why recent samples have been determined total coliform positive. During this visit, you posted the required public notice in anticipation of having this violation because 4 of 5 routine samples collected on August 28, 2013 were determined total coliform positive. A monthly MCL occurs when more than one sample collected during the month is determined total coliform positive. Additionally, 2 of the 4 repeat samples collected during the visit on September 4, 2013 were determined total coliform positive. You have already complied with the public notice requirement, as stated above.
- 3. Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 330-963-1237.

Sincerely,

Pamela L. Korenewych, Environmental Specialist
Division of Drinking and Ground Waters

cc: Columbiana County Health Department

PLK/ams