



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

September 10, 2013

RE: **NOTICE OF VIOLATION**  
HOLMES COUNTY  
HILLTOP GROUP HOME, INC.  
COMMUNITY WATER SYSTEM  
PWS ID # OH3800412

Mr. David Bird  
Hilltop Group Home Inc. PWS  
P.O. Box 32  
Millersburg, OH 44654

**CERTIFIED MAIL**

Dear Mr. Bird:

This letter is notification that the Hilltop Group Home Inc. public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Hilltop Group Home Inc. PWS as reported on Monthly Operating Report (MOR) #5002 for July 2013. Results reported on the form indicated thirteen (13) days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual or no result was reported.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer within 30 days from the date of this letter.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

A handwritten signature in blue ink, appearing to read "J. Robert Henn". The signature is fluid and cursive, written over the word "Respectfully,".

J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ans

cc: Kim Eters, Ohio EPA, NEDO, DDAGW