





John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Fulton County  
Old Pines Golf Club  
TNC Water System  
PWS ID # OH2633312

September 11, 2013

Ms. Deanna Guthrie  
Old Pines Golf Club  
12261 County Road 13  
Wauseon, Ohio 43567

Dear Ms. Guthrie:


This letter will confirm removal of the water use advisory required in our letter dated August 22, 2013. This is based on one set of four total coliform negative (safe) samples collected September 3, 2013.

This office has not received a copy of the public notice, which was issued. Send a copy of the public notice along with the verification form to the Ohio EPA, 347 North Dunbridge Road, Bowling Green, OH 43402 by September 25, 2013.

When a public water system monitoring with fewer than five routine samples per month has one or more total coliform-positive samples, the public water system shall monitor with at least five samples during the next month that the system provides water to the public. It is the responsibility of the water system to collect five samples during the month of September 2013.

If you have any questions, feel free to contact me at 419-373-3105 or by e-mail at [curt.eldridge@epa.ohio.gov](mailto:curt.eldridge@epa.ohio.gov).

Yours truly,

  
Curtis Eldridge  
Division of Drinking and Ground Waters

/cg

pc: Fulton County Health Department  
DDAGW, NWDO

