



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



September 10, 2013

RE: **NOTICE OF VIOLATION**  
SUMMIT COUNTY  
HIGHPOINT VILLA APARTMENTS  
COMMUNITY WATER SYSTEM  
PWS ID # OH7709012

Mr. & Mrs. Jeff Nathaniel  
P.O. Box 27  
Clinton, OH 44214

Dear Mr. & Mrs. Nathaniel:

This letter is notification that the Highpoint Villa Apartments public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01(F) which states that a public water system that provides water treated with chlorine shall monitor for free or combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point or points in the distribution system.

This violation of the OAC is based upon information submitted by the Highpoint Villa Apartments PWS as reported on Monthly Operating Report (MOR) #5002 for July 2013. Results reported on the form indicated 9 days where no result was reported.

An evaluation/investigation should be conducted to determine why no result was collected and what corrective action is necessary. Please provide your findings to this writer within 30 days from the date of this letter.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn  
Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

cc: Kim Eppers, Ohio EPA, NEDO, DDAGW