



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



September 17, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

Ms. Lynn Granata  
Arrowhead Mobile Home Park  
990 Beach Avenue-Suite 114  
Vancouver, B.C., Canada V6Z 2N9

Lucas County  
Arrowhead Mobile Home Park  
Community PWS  
PWS ID: OH4800112

Dear Ms. Granata:

Arrowhead Mobile Home Park is in violation of Ohio Revised Code Chapter 6109 as follows:

1. In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were two (2) weeks during the month of July 2013, and one (1) week during the month of August 2013, in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01(F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

If you have any questions, please contact me at (419) 373-3107 or by e-mail at [elizabeth.ames@epa.ohio.gov](mailto:elizabeth.ames@epa.ohio.gov).

Sincerely,

Elizabeth Ames  
Division of Drinking and Ground Waters  
/l/r

pc: Lucas County Health Department  
DDAGW – NWDO

ec: Ohio Manufactured Homes Commission

