



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



September 17, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

Ms. Julie Vantaggi  
Mohican River Estates  
6 Corporation Center  
Broadview Heights, Ohio 44147

Ashland County  
Mohican River Estates  
Community PWS  
PWS ID: OH0301312

Dear Ms. Vantaggi:

Mohican River Estates is in violation of Ohio Revised Code Chapter 6109 as follows:

1. In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There was one (1) week during the month of July 2013, and one (1) week during the month of August in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01(F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for manganese does not require public notification. Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.

If you have any questions, please contact me at (419) 373-3107 or by e-mail at [elizabeth.ames@epa.ohio.gov](mailto:elizabeth.ames@epa.ohio.gov).

Sincerely,

Elizabeth Ames  
Division of Drinking and Ground Waters  
/lr

pc: Ashland County Health Department  
DDAGW – NWDO

ec: Ohio Manufactured Homes Commission

