



State of Ohio Environment OH1237512 HOP BAR

1040 02 07/11/08

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-2752  
www.epa.ohio.gov



**NOTICE OF VIOLATION – ACTION REQUIRED**

July 14, 2008

Certified Mail

91 7108 2133 3931 0972 7828

Hop Bar  
Hop Bar  
213 Lyle Ave,  
Springfield, OH 45505

Clark County  
Hop Bar  
~~Transient-Non-Community PWS~~  
PWS ID: OH1237512  
Facility ID: 1253292

**Subject: Violation of Maximum Contaminant Level for Nitrate**

The Hop Bar is in violation for exceeding the maximum contaminant level (MCL) for nitrate in drinking water during Second Quarter of 2008. The Ohio Administrative Code (OAC) establishes an MCL of 10 milligrams per liter (mg/L) for nitrate. The nitrate concentration was 12 mg/L for the sample(s) collected on 6/24/2008.

**As a result of receiving a MCL violation, your system must take the following actions:**

1. Issue public notice to inform consumers of the MCL violation within 24 hours from notification as specified by the enclosed instructions. The enclosed public notice may be used to meet this requirement. If you wish to change the notice, contact this office prior to issuance; **AND**
2. Complete the enclosed verification form and send it with a copy of the issued public notice to my attention at the above mailing address; **AND**
3. Continue to perform quarterly monitoring for nitrate during each calendar quarter (January 1 - March 31; April 1 - June 30; July 1 - September 30; October 1 - December 31).

If you have any questions or wish to revise any of the notices, please call me at (614) 644-2752.

Sincerely,

Justin Burke  
Compliance Assurance Section

Enclosure: Laboratory List, Public Notices, Verification Form

cc: District Office Manager; District: SWDO, DDAGW; Clark County Health Dept

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

# DRINKING WATER WARNING

The Hop Bar water has high levels of nitrate

**DO NOT GIVE THE WATER TO INFANTS UNDER 6 MONTHS OLD  
OR USE IT TO MAKE INFANT FORMULA OR JUICE**

Results from water samples collected on 6/24/2008 showed nitrate levels of 12 mg/L. This is above the nitrate standard, or maximum contaminant level (MCL), of 10 mg/L. Nitrate in drinking water is a serious health concern for infants less than six months old.

## What should I do?

- **DO NOT GIVE THE WATER TO INFANTS.** *Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.* Blue baby syndrome is indicated by blueness of the skin. Symptoms in infants can develop rapidly, with health deteriorating over a period of days. If symptoms occur, seek medical attention immediately.
- Formula for children under six months of age should not be prepared with tap water. Instead, use bottled water or other water low in nitrates when preparing infant formula until further notice.
- **DO NOT BOIL THE WATER.** Boiling, freezing, filtering, or letting water stand does not reduce the nitrate level. Excessive boiling can make the nitrates more concentrated, because nitrates remain behind when the water evaporates.
- Adults and children older than six months can drink the tap water (nitrate is a concern for infants because they can't process nitrates in the same way adults can). However, if you are pregnant, nursing or have specific health concerns, you may wish to consult your doctor.

## What happened? What is being done?

Nitrate in drinking water can come from natural, industrial, or agricultural sources (including septic systems and run-off). Levels of nitrate in drinking water can vary throughout the year. We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact:

Contact Person: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*