



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



## NOTICE OF VIOLATION – ACTION REQUIRED

Re: Richland County  
Pin Oaks Estates MHP  
Community Water System  
PWS ID# OH7003812

September 26, 2013

Mr. John Szalay, Owner  
Pin Oaks Estates MHP  
581 Lake of The Woods  
Akron, Ohio 44333

Dear Mr. Szalay:

*Ohio Administrative Code, Rule 3745-83-01* requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system.

Review of your August, 2013 operational reports indicate that free chlorine residuals were below this level a total of 5 days.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with *OAC Rule 3745-83-01*.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at [curt.eldridge@epa.state.oh.us](mailto:curt.eldridge@epa.state.oh.us).

Yours truly,

Curtis Eldridge, Environmental Specialist 2  
Division of Drinking and Ground Water

/llr

pc: Richland County Health Department  
DDAGW/NWDO File

