



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



\* D D G W O H 2 6 D 0 4 1 2 8 5 3 0 4 1 2 \*

September 26, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

Ms. Amy Metz  
Village of Fayette  
125 West Main Street  
P. O. Box 87  
Fayette, Ohio 43521-0087

Fulton County  
Village of Fayette  
Community PWS  
PWS ID: OH2600412

Dear Ms. Metz:

The Village of Fayette is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for iron which is 0.3 mg/L. All four weeks during the month, iron exceeded the secondary standard.


Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

The Village of Fayette must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by September 30, 2013.

If you have any questions, please contact me at (419) 373-3105 or by e-mail at [curt.eldridge@epa.ohio.gov](mailto:curt.eldridge@epa.ohio.gov).

Sincerely,

  
Curtis Eldridge  
Division of Drinking and Ground Waters

/llr

pc: Fulton County Health Department  
DDAGW – NWD File

