



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

Re: Hancock County
ODOT RA SB
TNC Water System
PWS ID# OH3243812

September 26, 2013

Mr. Tony Lotz
ODOT
1885 North McCullough Street
Lima, Ohio 45801

Dear Mr. Lotz:

Ohio Administrative Code, Rule 3745-83-01 requires that each community and major non-community water system maintain a minimum of 0.2 mg/l free chlorine residual measured at representative points throughout the distribution system

Review of your August, 2013 operational reports indicate that free chlorine residuals were below this level a total of 6 days in August, 2013.

An investigation needs to be made to find the cause of these low chlorine residuals and steps need to be taken to bring the water system back to compliance with *OAC Rule 3745-83-01*.

Please note that additional information concerning existing and upcoming drinking water regulations and requirements can be obtained from our Web site at <http://www.epa.ohio.gov>. If you have any questions regarding this letter, or any other matter involving your water system, please feel free to contact me at 419-373-3105 or via email at curt.eldridge@epa.state.oh.us.

Yours truly

Curtis Eldridge, Environmental Specialist 2
Division of Drinking and Ground Water

/llr

pc: Hancock County Health Department
DDAGW/NWDO File

