



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



September 25, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Mr. Tracy Evans
P. O. Box 305
Leesburg, Ohio 45135

**RE: HIGHLAND COUNTY
LEESBURG VILLAGE
COMMUNITY PWS
PWS ID: OH3600712**

Dear Mr. Evans:

Leesburg Village is in violation of Ohio Revised Code Chapter 6109 as follows:

Failure to maintain the minimum required (free or combined) chlorine residual in the distribution system

In violation of OAC 3745-83-01 (C)(1), the public water system failed to maintain the minimum required (free/combined) chlorine residual in the distribution system. The residual disinfectant concentration of the drinking water at representative points throughout the distribution systems was less than two-tenths milligram per liter free chlorine / one milligram per liter combined chlorine. There were 6 days during the month of June 2013 in which the minimum chlorine residual was not maintained.

Leesburg Village must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required within forty-five (45) days from the date of this letter.

If you have any questions, please contact me at (937) 285-6118.

Sincerely,

Gina Hayes
Environmental Specialist
Division of Drinking and Ground Waters

cc: Highland County Health Department

GH\bp