



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Crawford County
City of Galion
Community Water System
PWS OH1700211

RECEIVED

JAN 14 2008

D.D.A.G.W.

January 11, 2008

Tim Parks
City of Galion
301 Harding Way E
Galion OH 44833-2087

OH1700211 GALION CITY

2920 27 01/11/08



Subject: TOC Monitoring NOV

Dear Mr. Parks:

This letter is notification that your public water system is in violation of rule 3745-81-77 of the Ohio Administrative Code (OAC) as follows:

Violation:	Failure to monitor and/or report analytical results for total organic carbon and/or alkalinity
Period of Violation:	[December 2007]
The system failed to monitor and/or report analytical results for total organic carbon in the source/finished water.	

User Notification Required You must notify your water users of this monitoring violation in accordance with rule 3745-81-32 of the OAC. Refer to the enclosures for instructions, an example public notice, and a verification form.

Violations are subject to potential enforcement actions that may include civil penalties of not more than \$25,000 per day per violation in accordance with RC §§6109.33, or an administrative penalty in accordance with rule 3745-81-04.

Mr. Tim Parks
January 11, 2008
Page Two

If you have any questions regarding this letter or any other matter involving your water system, please feel free to contact me at (419)373-3048 or via email [Ralph.Baker@epa.state.oh.us].

Sincerely,



Ralph J. Baker
Engineer
Division of Drinking and Ground Waters

/lb

pc: Kate Siefert, Crawford County General Health District
Stephanie Zmuda, Galion City Health Department
~~Joni Buchanan, DDAGW, CO~~
File

ec Ralph Baker, DDAGW, NWDO