



State of Ohio Environm: OH1503112 WHITE STONE MINISTRIES 2456 02 02/12/09

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-2752  
www.epa.ohio.gov



**NOTICE OF VIOLATION – ACTION REQUIRED**

February 13, 2009

CERTIFIED MAIL

Pleasant View Nursing Home  
Pleasant View Nursing Home  
7451 Pleasant View Drive,  
Lisbon, OH 44432

Columbiana County  
Pleasant View Nursing Home  
Public Community PWS  
PWS ID: OH1503112

**Subject: Violation of Maximum Contaminant Level for TOTAL HALOACETIC ACIDS (HAA5)**

Pleasant View Nursing Home is in violation for exceeding the maximum contaminant level (MCL) standard of 0.060 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TOTAL HALOACETIC ACIDS (HAA5). Compliance with the MCL is based on a running annual average. The annual average for TOTAL HALOACETIC ACIDS (HAA5) during the Fourth Quarter of 2008 time period is 0.088 MG/L.

To address the MCL violation, Pleasant View Nursing Home is required to take the following actions:

- Notify your customers within 30 days using the enclosed instructions and public notice.
- Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
- Perform quarterly monitoring for TOTAL HALOACETIC ACIDS (HAA5) during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
- Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly  
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form  
cc: DDAGW-NEDO; DDAGW-CO file; Columbiana County Health Department

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

91 7108 2133 3931 0973 6349

# DRINKING WATER NOTICE

## Pleasant View Nursing Home Has Levels of TOTAL HALOACETIC ACIDS (HAA5) Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TOTAL HALOACETIC ACIDS (HAA5). The average level of TOTAL HALOACETIC ACIDS (HAA5) over the last four quarters was 0.088 MG/L. The standard for TOTAL HALOACETIC ACIDS (HAA5) is 0.060 MG/L.

### What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing TOTAL HALOACETIC ACIDS (HAA5) in excess of the MCL over many years may have an increased risk of getting cancer.

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID: OH1503112

Date Distributed: \_\_\_\_\_