



State of Ohio Environrr

OH1503112

WHITE STONE MINISTRIES

2456

02 08/12/09

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-2752;
www.epa.



* 0 H 1 5 0 3 1 1 2 8 0 8 7 9 1 2 *

NOTICE OF VIOLATION – ACTION REQUIRED

August 12, 2009

CERTIFIED MAIL

91 7108 2133 3931 0972 5190

Liz Shutler
Pleasant View Nursing Home
7451 Pleasant View Drive,
Lisbon, OH 44432

Columbiana County
Pleasant View Nursing Home
Community PWS
PWS ID: OH1503112
Facility ID: DS1

Subject: Violation of Maximum Contaminant Level for TOTAL HALOACETIC ACIDS (HAA5)

Pleasant View Nursing Home is in violation for exceeding the maximum contaminant level (MCL) standard of 0.060 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for HAA5. Compliance with the MCL is based on a running annual average. The annual average for HAA5 during the Second Quarter of 2009 time period is 0.135 MG/L.

To address the MCL violation, Pleasant View Nursing Home is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for HAA5 during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly,
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form
cc: Manager; DDAGW file; NEDO file; Columbiana County Health Department

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

DRINKING WATER NOTICE

Pleasant View Nursing Home Has Levels of TOTAL HALOACETIC ACIDS (HAA5) Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for HAA5. The average level of HAA5 over the last four quarters was 0.135 MG/L. The standard for HAA5 is 0.060 MG/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: _____

PWSID: OH1503112 Facility ID: DS1

Monitoring Period: Second Quarter of 2009