



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Re: Crawford County Lee Fisher, Lieutenant Governor  
Village of New Washington Chris Korleski, Director  
Community Water System  
PWS ID# 1700411

May 14, 2007

RECEIVED

MAY 17 2007

Mr. Norman Lucius, BPA Chairman  
Village of New Washington  
119 East Mansfield Street  
P.O. Box 217  
New Washington, Ohio 44854

OH1700411 NEW WASHINGTON VILLAGE 2920 27 05/14/07

A.G.W.



Dear Mr. Lucius:

**SUBJECT:** Notice of violation - Failure to monitor and report analytical results for total organic carbon and alkalinity.

This letter is notification that your public water system is in violation of Ohio Administrative Code (OAC) rule 3745-81-77 as follows:

|   |  |
|---|--|
| <b>Violation:</b> Failure to monitor and report analytical results for total organic carbon and alkalinity                  |  |
| <b>Period of Violation:</b> January 2007  |  |
| The system failed to monitor and report analytical results for total organic carbon in the source water and finished water. | The system failed to monitor and report analytical results for alkalinity in the source water. |

**User Notification Required.** You must notify your water users of this monitoring violation in accordance with OAC rule 3745-81-32. Refer to the enclosures for instructions, an example public notice, and a verification form.

If you have any questions regarding this letter, I can be reached at (419) 373-4118.

Sincerely,

Justin W. Bowerman  
Division of Drinking and Ground Waters

//lr

pc: Tom Niedermier, Mayor (include enclosures)  
Crawford County Health Department  
~~David Evans, DDAGW, E&OS, CO~~  
Todd Kelleher, DDAGW, CO  
DDAGW, NWDO, File (include enclosures)

RECEIVED  
MAY 1 1964  
C.D.A.G.M.