



STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-2752 FAX:  
www.epa.state.



**NOTICE OF VIOLATION – ACTION REQUIRED**

May 15, 2008

CERTIFIED MAIL

World Harvest Church  
World Harvest Bible College PWS  
4595 Gender Rd,  
Canal Winchester, OH 43110

Fairfield County  
World Harvest Bible College PWS  
~~Non-Transient~~ Non Community PWS  
PWS ID: OH2351912  
Facility ID: 2362056

**Subject: Violation of Maximum Contaminant Level for 1,2-DICHLOROPROPANE**

World Harvest Bible College PWS is in violation for exceeding the maximum contaminant level (MCL) standard of 0.005 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for 1,2-DICHLOROPROPANE. Compliance with the MCL is based on a running annual average. The annual average for 1,2-DICHLOROPROPANE during the Fourth Quarter of 2007 time period is 0.023 MG/L and during the First Quarter of 2008 is 0.017 MG/L.

**To address the MCL violation, World Harvest Bible College PWS is required to take the following actions:**

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for 1,2-DICHLOROPROPANE during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly  
Division of Drinking and Ground Waters

Enclosure: Public Notice, Verification Form  
cc: Manager; CDO: DIV OF DRINKING AND GROUND WATER

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

# DRINKING WATER NOTICE

## World Harvest Bible College PWS Has Levels of 1,2-DICHLOROPROPANE Above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for 1,2-DICHLOROPROPANE. The average level of 1,2-DICHLOROPROPANE during the Fourth Quarter of 2007 time period is 0.023 MG/L and during the First Quarter of 2008 is 0.017 MG/L. The standard for 1,2-DICHLOROPROPANE is 0.005 MG/L.

### What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

### What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing 1,2-DICHLOROPROPANE in excess of the MCL over many years may have an increased risk of getting cancer.

### What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting the public water system:

Contact Person: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID: OH2351912    Facility ID: 2362056    Date Distributed: \_\_\_\_\_