



Environmental  
Protection Agency

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korfeski, Director

OH2600603 LYONS VILLAGE

2950 02 11/18/10



November 18, 2010

CERTIFIED MAIL

**NOTICE OF VIOLATION – ACTION REQUIRED**

Vicki Smith  
Lyons Village  
126 W Morenci St, Po Box 414  
Lyons, OH 43533

Fulton County  
Lyons Village  
Community PWS  
PWS ID: OH2600603

**Subject: Violation of Maximum Contaminant Level for TOTAL TRIHALOMETHANES (TTHM)**

Lyons Village is in violation for exceeding the maximum contaminant level (MCL) standard of 0.080 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TTHM. Compliance with the MCL is based on a running annual average. The annual average for TTHM during the Third Quarter of 2010 time period is 0.081 MG/L.

To address the MCL violation, Lyons Village is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for TTHM during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly  
Compliance Assurance Section  
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form  
cc: Manager; DDAGW file; NWDO file; Fulton County Health Department